

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair

Replace water damaged ceiling tiles in cafeteria

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Replace light bulbs in bathrooms 057 and 046.

At time of the inspection the foot candles are 15,4.5,0.3 at the bath stalls in bathroom 057 girls: and 7.5 foot candles in bathroom 046 girls.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Maria Adrover (047452)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 11/10/2022

Inspector Signature:

Handwritten signature of Maria Adrover.

Client Signature:

Handwritten signature of the client.